



Olene S. Walker
Governor
S. Camille Anthony
Executive Director
F. Keith Stepan
Director

State of Utah

Division of Facilities Construction & Management

Department of Administrative Services
4110 State Office Building
Salt Lake City, Utah 84114
Phone (801) 538-3018
Fax (801) 538-3267

MEMORANDUM

Date: 9 April 2004

To: Commissioning Consultants

From: Lyle Knudsen, DFCM

Reference: University of Utah
Health Sciences Education Building – Commissioning Selection
DFCM Project No. 02042750

Subject: **Addendum No. 1**

1.1. Will there be any review of the design/construction documents?

The contract documents will have to be reviewed to determine the scope of the services that are required by both the subcontractors and the commissioning agent. We have yet to determine the extent of the commissioning requirements to be performed by the subcontractor and how the agent will interface with the commissioning process.

1.2. Any smoke testing for atrium?

At this point the report for a ventilation approach to smoke evacuation appears to be favorable. We will pursue this as a solution. I would think that there will have to be verification of the solution a commissioning.

1.3. Any vivarium spaces?

No.

1.4. Each commissioning firm has been sent a copy of the construction schedule.

End of Addendum